

CE Declaration of Conformity



LEDspan Limited

This is to certify that the:



Product Designation: LED Lay-in Grid Fixture

Model Number : Standard & Emergency

LLIG1(8)-31W(E), LLIG1(8)-42W(E), LLIG1(8)-54W(E)
LLIG1(M)-31W(E), LLIG1(M)-42W(E), LLIG1(M)-54W(E)

Distributed by: LEDspan Limited, The Prince, Castlecomer, Kilkenny,
Rep. of Ireland. R95 X8ER

Using test standard:

- EN 55015:2019/A11:2020 - Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment .CISPR 15:2005
- EN 61000-3-2:2019 - Electromagnetic compatibility (EMC) -- Part 3-2:
Limits - Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)
- EN 61000-3-3:2013 - Electromagnetic compatibility (EMC) - Part 3-3: Limits -
Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection
- EN61547: 2009 - Equipment for general lighting purposes - EMC immunity requirements. IEC 61547:2009 + IS1:2013

Has been tested with the listed standards and found in compliance with
Electromagnetic Compatibility (EMC) Directive 2014/30/EU

Canice Kelly
Technical Manager



Issue date: 1st of August 2020